

Trilogy T2 DL2700

- A. Digital Locksets shall meet or exceed ANSI A156.2 Series 4000, Grade 1 standard for cylindrical lever locks. Locks shall be FCC Certified and listed UL10C Positive Pressure for "A" 3hour fire rated openings. Trim design shall be ADA compliant, chosen from manufacturers standard lever designs. Locks shall have a deadlocking latch bolt and be of the electronic battery digital type, with up to 17 available codes; 1 Master, 1 Management and 15 individual user codes. Furnish manufacturer's standard power pack with each lock; include batteries. Keypads shall be all metal with 12 buttons and programmable through the keypad. Locks shall have key override or the optional 2-wire remote release capability using the built in Form C relay output. Locks shall fit a standard ANSI A115.2 Series door preparation for Grade 1 locks modified by additional through-bolt holes. Locks shall be non-handed and provided with strikes as required. Provided with standard 6 pin cylinder, optional 6 or 7 pin, I.C. type core, is also available (See keying Requirements) Locks at exterior openings or wet areas, shall have the "WP" Waterproof Protection option. Provide proper fasteners for lock and strikes. Lock functions are as shown in hardware sets. Scheduled product is from Alarm Lock*, Trilogy model T2 DL2700 series. No approved equals.